

PUBLIC NOTIFICATION
IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER
TTHM VIOLATION AT The Grantville Water System

Our community water system recently violated a drinking water standard. Although this is not an emergency, as our customers, you have the right to know what happened, what you should do, and what we are doing to correct this situation. We routinely monitor for the presence of drinking water contaminants. We have been notified by the State that our water system exceeded the maximum contaminant levels (MCL) for the following:

| Violation ID | Compliance Period | Site # | Analyte | Concentration | MCL |
|--------------|----------------------------------|--------|---------|---------------|------------|
| 2025-22625 | 4Q2024 – 01/01/2025 – 03/31/2025 | 501 | TTHM | 0.082 mg/L | 0.080 mg/L |

What should I do? There is nothing you need to do at this time. You do not need to boil your water or take other corrective actions. Residents should not be alarmed and do not need to seek alternative water supplies. The supplier is taking corrective actions to ensure that adequate monitoring and reporting will be maintained.

What does this mean?

Some people who drink water containing Trihalomethanes in excess of the MCL over many years, may experience problems with their liver, kidneys, or central nervous system, and may have an increased risk of getting cancer. If you have a severely compromised immune system, have an infant, are pregnant, or are elderly, you may be at increased risk and should seek advice from your health care providers about drinking this water.

What happened? What is being done? Due in part to water aging issues inside the water distribution system, the City of Grantville exceeded the Maximum Contaminant Level (MCL) for Trihalomethanes. The City of Grantville has implemented an aggressive flushing program to reduce water aging in areas of the system where Trihalomethanes could be elevated at times during the year. Additionally, The City of Grantville has made changes recently to the water distribution system that should help prevent water aging in the system. The changes mentioned above will reduce and or eliminate Trihalomethanes in the system. **The City of Grantville expects to return to compliance by the second quarter of 2025.**

For more information, please contact Michael Ballew at (678) 675-0407.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is provided by: Grantville Water System
Water System ID: GA0770001
Date of public notice distributed: 03/20/2025